

General Environmental Incident Summary

Incident: 5472

Notice: 7/26/2017 1408

Occurred: 7/26/2017 0930

DEM Incident No:

No Further Action: ☒

Responsible Party: CHI St. Alexius Health

County: Burleigh

Twp Rng Sec Qtr: 138 80 3

Lat Long + Method: 46.80607 -100.77200 Interpolation from map

Location Description: CHI St. Alexius Health - Tech & Ed Building, 1310 East Main, Bismarck, ND 58501

Submitted By Info: Doris Weiss

CHI St Alexius Health

900 E Broadway Ave

Bismarck ND 58501

Received By Info:

Contact Info: Doris Weiss

900 East Broadway Ave

Bismarck ND 58501

Affected Medium: 09 - other

Near. Occupied Bldg: 50 Feet

Type of Incident: accidental dump of fuel while filling tanks

Release Contained: Yes

Reported to NRC: No

Contaminant: Diesel Fuel

Volume of Release: 30 gallons

Duration of Release: 10 minutes

Agriculture Related: No

EPA Extremely

Hazardous Substance: Unknown

Number of Fatalities: 0

Number of Injuries: 0

Cause of Incident:

filling tanks accidentally dumped 25-30 gallons of diesel fuel

Risk Evaluation:

None - fuel spilled on concrete and was cleaned up without impacting ground , water or other areas of contamination.

Potential Env. Impacts:

None

Action Taken/Planned:

Proper E9 was used to pick up the fuel and disposed of - chemical response bags were placed around fuel spill preventing it from entering city drains.

Wastes Disposal Location:

our dumpster

Other Agencies Involved:

NDDDES

Updates

Date: 7/26/2017 ***Status:*** Reviewed - No Action Required

Author: Stockdill, Scott

Notes:

According to the incident summary, this spill impacted an impermeable surface and was cleaned up immediately. No follow-up is necessary.

Updated Volume: None at the time of this update